ADDITIONAL STANDARDS FOR LICENSES, CERTIFICATIONS, AND REGULATORY AP-PROVALS

§ 50.120 Training and qualification of nuclear power plant personnel.

- (a) Applicability. The requirements of this section apply to each applicant for and each holder of an operating license issued under this part and each holder of a combined license issued under part 52 of this chapter for a nuclear power plant of the type specified in §50.21(b) or §50.22.
- (b) Requirements. (1)(i) Each nuclear power plant operating license applicant, by 18 months prior to fuel load, and each holder of an operating license shall establish, implement, and maintain a training program that meets the requirements of paragraphs (b)(2) and (b)(3) of this section.
- (ii) Each holder of a combined license shall establish, implement, and maintain the training program that meets the requirements of paragraphs (b)(2) and (b)(3) of this section, as described in the final safety analysis report no later than 18 months before the scheduled date for initial loading of fuel.
- (2) The training program must be derived from a systems approach to training as defined in 10 CFR 55.4, and must provide for the training and qualification of the following categories of nuclear power plant personnel:
 - (i) Non-licensed operator.
 - (ii) Shift supervisor.
 - (iii) Shift technical advisor.
- (iv) Instrument and control technician
 - (v) Electrical maintenance personnel.
- (vi) Mechanical maintenance personnel.
- (vii) Radiological protection technician.
 - (viii) Chemistry technician.
 - (ix) Engineering support personnel.
- (3) The training program must incorporate the instructional requirements necessary to provide qualified personnel to operate and maintain the facility in a safe manner in all modes of operation. The training program must be developed to be in compliance with the facility license, including all technical specifications and applicable regulations. The training program must be periodically evaluated and revised

as appropriate to reflect industry experience as well as changes to the facility, procedures, regulations, and quality assurance requirements. The training program must be periodically reviewed by licensee management for effectiveness. Sufficient records must be maintained by the licensee to maintain program integrity and kept available for NRC inspection to verify the adequacy of the program.

[72 FR 49505, Aug. 28, 2007]

§ 50.150 Aircraft impact assessment.

- (a) Assessment requirements. (1) Assessment. Each applicant listed in paragraph (a)(3) shall perform a design-specific assessment of the effects on the facility of the impact of a large, commercial aircraft. Using realistic analyses, the applicant shall identify and incorporate into the design those design features and functional capabilities to show that, with reduced use of operator actions:
- (i) The reactor core remains cooled, or the containment remains intact; and
- (ii) spent fuel cooling or spent fuel pool integrity is maintained.
- (2) Aircraft impact characteristics.¹ The assessment must be based on the beyond-design-basis impact of a large, commercial aircraft used for long distance flights in the United States, with aviation fuel loading typically used in such flights, and an impact speed and angle of impact considering the ability of both experienced and inexperienced pilots to control large, commercial aircraft at the low altitude representative of a nuclear power plant's low profile.
- (3) Applicability. The requirements of paragraphs (a)(1) and (a)(2) of this section apply to applicants for:
- (i) Construction permits for nuclear power reactors issued under this part after July 13, 2009;
- (ii) Operating licenses for nuclear power reactors issued under this part for which a construction permit was issued after July 13, 2009;
- (iii)(A) Standard design certifications issued under part 52 of this chapter after July 13, 2009;

¹Changes to the detailed parameters on aircraft impact characteristics set forth in guidance shall be approved by the Commission

§ 50.150

- (B) Renewal of standard design certifications in effect on July 13, 2009 which have not been amended to comply with the requirements of this section by the time of application for renewal:
- (iv) Standard design approvals issued under part 52 of this chapter after July 13, 2009;
- (v) Combined licenses issued under part 52 of this chapter that:
- (A) Do not reference a standard design certification, standard design approval, or manufactured reactor; or
- (B) Reference a standard design certification issued before July 13, 2009 which has not been amended to address the requirements of this section; and
- (vi) Manufacturing licenses issued under part 52 of this chapter that:
- (A) Do not reference a standard design certification or standard design approval: or
- (B) Reference a standard design certification issued before July 13, 2009 which has not been amended to address the requirements of this section.
- (b) Content of application. For applicants identified in paragraph (a)(3) of this section, the preliminary or final safety analysis report, as applicable, must include a description of:
- (1) The design features and functional capabilities identified in paragraph (a)(1) of this section; and
- (2) How the design features and functional capabilities identified in paragraph (a)(1) of this section meet the assessment requirements in paragraph (a)(1) of this section.
- (c) Control of changes. (1) For construction permits which are subject to paragraph (a) of this section, if the permit holder changes the information required by 10 CFR 50.34(a)(13) to be included in the preliminary safety analysis report, then the permit holder shall consider the effect of the changed feature or capability on the original assessment required by 10 CFR 50.150(a) and amend the information required by 10 CFR 50.34(a)(13) to be included in the preliminary safety analysis report to describe how the modified design features and functional capabilities continue to meet the assessment requirements in paragraph (a)(1) of this sec-

- (2) For operating licenses which are subject to paragraph (a) of this section, if the licensee changes the information required by 10 CFR 50.34(b)(12) to be included in the final safety analysis report, then the licensee shall consider the effect of the changed feature or capability on the original assessment required by 10 CFR 50.150(a) and amend the information required by 10 CFR 50.34(b)(12) to be included in the final safety analysis report to describe how the modified design features and functional capabilities continue to meet the assessment requirements in paragraph (a)(1) of this section.
- (3) For standard design certifications which are subject to paragraph (a) of this section, generic changes to the information required by 10 CFR 52.47(a)(28) to be included in the final safety analysis report are governed by the applicable requirements of 10 CFR 52.63
- (4)(i) For combined licenses which are subject to paragraph (a) of this section, if the licensee changes the information required by 10 CFR 52.79(a)(47) to be included in the final safety analysis report, then the licensee shall consider the effect of the changed feature or capability on the original assessment required by 10 CFR 50.150(a) and amend the information required by 10 CFR 52.79(a)(47) to be included in the final safety analysis report to describe how the modified design features and functional capabilities continue to meet the assessment requirements in paragraph (a)(1) of this section.
- (ii) For combined licenses which are not subject to paragraph (a) of this section but reference a standard design certification which is subject to paragraph (a) of this section, proposed departures from the information required by 10 CFR 52.47(a)(28) to be included in the final safety analysis report for the referenced standard design certification are governed by the change control requirements in the applicable design certification rule.
- (iii) For combined licenses which are not subject to paragraph (a) of this section but reference a manufactured reactor which is subject to paragraph (a) of this section, proposed departures from the information required by 10 CFR 52.157(f)(32) to be included in the

Pt. 50, App. A

Number

Nuclear Regulatory Commission

final safety analysis report for the manufacturing license are governed by the applicable requirements in 10 CFR 52.171(b)(2).

(5)(i) For manufacturing licenses which are subject to paragraph (a) of this section, generic changes to the information required by 10 CFR 52.157(f)(32) to be included in the final safety analysis report are governed by the applicable requirements of 10 CFR 52.171.

(ii) For manufacturing licenses which are not subject to paragraph (a) of this section but reference a standard design certification which is subject to paragraph (a) of this section, proposed departures from the information required by 10 CFR 52.47(a)(28) to be included in the final safety analysis report for the referenced standard design certification are governed by the change control requirements in the applicable design certification rule.

[74 FR 28146, June 12, 2009]

APPENDIX A TO PART 50—GENERAL DESIGN CRITERIA FOR NUCLEAR POWER PLANTS

Table of Contents

INTRODUCTION

DEFINITIONS

Nuclear Power Unit. Loss of Coolant Accidents. Single Failure. Anticipated Operational Occurrences.

CRITERIA

	Number
I. Overall Requirements:	
Quality Standards and Records	1
Design Bases for Protection Against Natural Phenomena	2
Fire Protection	3
Environmental and Dynamic Effects Design	
Bases	4
Sharing of Structures, Systems, and Compo-	
nents	5
II. Protection by Multiple Fission Product Barriers:	
Reactor Design	10
Reactor Inherent Protection	11
Suppression of Reactor Power Oscillations	12
Instrumentation and Control	13
Reactor Coolant Pressure Boundary	14
Reactor Coolant System Design	15
Containment Design	16
Electric Power Systems	17
Inspection and Testing of Electric Power	
Systems	18
Control Boom	19

CRITERIA—Continued

III. Books the good Bookhite Control Control	
III. Protection and Reactivity Control Systems:	00
Protection System Functions	20
Protection System Reliability and Testability Protection System Independence	21 22
Protection System Failure Modes	23
Separation of Protection and Control Sys-	23
tems	24
Protection System Requirements for Reac-	
tivity Control Malfunctions	25
Reactivity Control System Redundancy and	
Capability	26
Combined Reactivity Control Systems Capa-	
bility	27
Reactivity Limits	28
Protection Against Anticipated Operational	
Occurrences	29
IV. Fluid Systems:	
Quality of Reactor Coolant Pressure Bound-	00
ary	30
Fracture Prevention of Reactor Coolant Pressure Boundary	31
	31
Inspection of Reactor Coolant Pressure Boundary	32
Reactor Coolant Makeup	33
Residual Heat Removal	34
Emergency Core Cooling	35
Inspection of Emergency Core Cooling Sys-	00
tem	36
Testing of Emergency Core Cooling System	37
Containment Heat Removal	38
Inspection of Containment Heat Removal	
System	39
Testing of Containment Heat Removal Sys-	
tem	40
Containment Atmosphere Cleanup	41
Inspection of Containment Atmosphere	
Cleanup Systems	42
Testing of Containment Atmosphere Cleanup	40
Systems	43
Cooling Water	44
Inspection of Cooling Water System	45 46
Testing of Cooling Water System	46
V. Reactor Containment:	
Containment Design Basis	50
Fracture Prevention of Containment Pressure	
Boundary	51
Capability for Containment Leakage Rate	
Testing	52
Provisions for Containment Testing and In-	
spection	53
Systems Penetrating Containment	54
Reactor Coolant Pressure Boundary Pene-	
trating Containment	55
Primary Containment Isolation	56
Closed Systems Isolation Valves	57
VI Final and Badiosethills Control	
VI. Fuel and Radioactivity Control:	
Control of Releases of Radioactive Materials	60
to the Environment	60
Fuel Storage and Handling and Radioactivity Control	61
Prevention of Criticality in Fuel Storage and	51
Handling	62
Monitoring Fuel and Waste Storage	63
Monitoring Radioactivity Releases	64
,	